

Public Notification Language Notice of Drinking Water Treatment Technique Violation(s)

CITY OF LADONIA TX 0740004 has violated the treatment technique requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of that monitoring to the TCEQ on a quarterly basis.

Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. During SEPTEMBER, OCTOBER, AND NOVEMBER 2018, sufficient levels of chlorine residual were not met in more than five percent (5%) of monthly samples.

The following actions are being taken to address this issue:

The City of Ladonia adds chlorine to the water before distributing to the community. On September 24, 2018, the City of Ladonia experienced water outage due to construction. A boil water notice was issued on September 26, revised on October 1, and re-issued on December 26, 2018. During this time, the chlorine pump was not operational. The BWN was rescinded January 14, 2019.

The City of Ladonia has repaired the chlorine pump and is now operational.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact City of Ladonia at 903-367-7011.

Posted/Delivered on: 10-23-2019